

Tender Number: T14/03/19

Tender description: SUPPLY & INSTALLATION OF FIRE DETECTION AND PROTECTION EQUIPMENT AT IDC HEAD OFFICE

Question and Answers version 1

No.	Question	Type	Answer
1	On the sprinklers - what make of alarm valves do you have – any specific brand of sprinkler heads you require ?	Technical	Alarm valves are Viking. The sprinkler heads must have two international approvals such as Viking or similar approved.
2	On the Gas suppression – BOQ 5 requires 4 cylinders but asks for a 5 port manifold		The manifold should be a 4 port - refer to No 9 below
3	Will the drawings still be sent to us for the server rooms	Technical	Yes, should receive by Fr, 29 March
4	Please can you confirm that only the EN54 approved extinguishent control panel are to be used	Technical	Gas control panels to be EN 54 approved
5	Gaseous Suppression Systems to be Inert gas	Technical	(IG 541 or IG 55) such as Inergen or Argonite
6	At the site briefing	Technical	Acoustic nozzles are to be installed in gas suppression areas
7	All the gas control units that are required as addressable units – these do not comply with EN54 – we suggest conventional units EN54 approved with conventional detectors and then interfaced to the Ziton fire system	Technical	Gas suppression rooms to have conventional devices to be interfaced with the main smoke detection system
8	At the site briefing	Technical	Saddle spacing on conduit to be 500 mm
9	BOQ_04 IDC Nerve Centre Item 3.2.1 should be corrected to read	Technical	4 cylinder manifold piping ETC
9	I wanted to ask you - there was a request for an extension. Is this possible	Technical	Closing date will not extended, 3rd April 2019 is realistic