

Tender Number: T24/05/19

Tender description: Request for Proposal for Datacentre Hosting Facilities

Question and Answers

No.	Question	Type	Answer
1	How much power is required for the rack (they have listed 4 x caravan plugs but no actual power requirement)	Technical	Power utilisation cost for 3.5KV
2	The tender have requested 1 x 42u rack but have also asked for a 45sqm cage – there is a massive pricing difference between these two – do you want a cabinet with reserved space for growth or do you specifically require a cage?	Technical	The bidder must provide the rack with extra space to accommodate changing environments and to cater for growth.
3	If the requirement is a cage, do you require biometrics and CCTV	Technical	The datacentre must have have biometrics access control and CCTV for security purposes.
4	Will the IDC supply their own PDU's or will the 8 port non poms suffice (or do these need to be upgraded to 24 ports)?	Technical	The IDC need to upgrade to 24 ports , bidders to supply